

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Endure Floodlight

Name and address of the applicant

Fast Cables Limited
192-Y Commercial Area, Sector Y DHA Phase 3, Lahore, 54000 Punjab,
Pakistan

Name and address of the manufacturer

Fast Cables Limited
192-Y Commercial Area, Sector Y DHA Phase 3, Lahore, 54000 Punjab,
Pakistan

Name and address of the factory

Fast Cables Limited
192-Y Commercial Area, Sector Y DHA Phase 3, Lahore, 54000 Punjab,
Pakistan*When more than one factory*☒ Additional information on page 2

Ratings and principal characteristics

Product dataRatings: 220-240 V, 50/60 Hz, ta 50 °C, Class I, IP66, Non-user
replaceable LEDs,
Other details refer to Attachment 1: Detailed model list of test report.

Trademark / Brand (if any)



Fast LIGHTS

Customer's Testing Facility (CTF) Stage
used

Model / Type Ref.

FL10 50W x70 yD, FL11 100W x70 yD, FL12 120W x70 yD,
FL12 150W x70 yD, FL13 200W x70 yD and FL14 300W x70 yD

Additional information


☒ Additional information on page 2A sample of the product was tested and
found to be in conformity with

IEC 60598-1:2020 and IEC 60598-2-5:2015

National differences:
EU Group DifferencesAs shown in the Test Report Ref. No.
which forms part of this Certificate

4917084.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-08-08

Signature: C Jwo