



Ref. Certif. No.

NL-109749

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Endure Highbay

Name and address of the applicant

Fast Cables Limited
192-Y Commercial Area, Sector Y DHA Phase 3, Lahore, 54000 Punjab,
Pakistan

Name and address of the manufacturer

Fast Cables Limited
192-Y Commercial Area, Sector Y DHA Phase 3, Lahore, 54000 Punjab,
Pakistan

Name and address of the factory

Fast Cables Limited
192-Y Commercial Area, Sector Y DHA Phase 3, Lahore, 54000 Punjab,
Pakistan*When more than one factory*☒ Additional information on page 2

Ratings and principal characteristics

Product dataRatings: AC 220-240 V, 50/60 Hz, Class I, IP65,
ta: 50 °C, non-user replaceable LEDs;
Refer to Attachment 1: Detailed model list of test report for other details.

Trademark / Brand (if any)



Fast LIGHTS

Customer's Testing Facility (CTF) Stage
used

Model / Type Ref.

BA10 100W x80 yD LF FHB AB z, BA10 120W x80 yD LF FHB AB z,
BA10 90W x80 yD LF FHB AB z, BA11 150W x80 yD LF FHB AB z,
BA12 200W x80 yD LF FHB AB z and BA12 240W x80 yD LF FHB AB z

Additional information

☒ Additional information on page 2A sample of the product was tested and
found to be in conformity with

IEC 60598-1:2020 and IEC 60598-2-1:2020

National differences:

EU Group Differences, EU Special National Conditions

As shown in the Test Report Ref. No.
which forms part of this Certificate

4917085.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2024-08-06

Matilde Tonsi

Signature: MT Tonsi

