

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Fast Cables Ltd.,

Lahore, Pakistan

has successfully passed the type test sequence on a single-core

power cable

Type: CU/XLPE/PVC/AWA/PVC

Rating: 0,6/1(1,2) – 1x300 mm² – Cu - XLPE

The test object passed the specification of test duties of

IEC 60502-1

Subclause 17 & 18

The test results are recorded in Certificate No.

1231-17

This Certificate was issued on 30 June 2017

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA
Laboratories

