

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

Fast Cables Ltd.,

Lahore, Pakistan

has successfully passed the type test sequence on a three-core

power cable

Type: 3 x 400 mm² AL/XLPE/CTS/PVC/SWA/PVC 15 KV

Rating: 8,7/15(17,5) – 3x400 mm² – AL - XLPE

The test object passed the specification of test duties of

IEC 60502-2

The test results are recorded in Certificate No.

1244-17

This Certificate was issued on 3 July 2017

DNV GL Netherlands B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA

Laboratories

